



0000163506

RECEIVED

2015 JUN 30 P 3:27

AZ CORP COMMISSION
DOCKET CONTROL

ORIGINAL

Steve Wene, No. 019630
MOYES SELLERS & HENDRICKS LTD.
1850 N. Central Avenue, Suite 1100
Phoenix, Arizona 85004
(602)-604-2189
swene@law-msh.com
Attorneys for Naco Water Company, LLC

BEFORE THE ARIZONA CORPORATION COMMISSION

Arizona Corporation Commission

DOCKETED

JUN 30 2015

COMMISSIONERS

SUSAN BITTER SMITH, CHAIRMAN
BOB STUMP
BOB BURNS
TOM FORESE
DOUG LITTLE

DOCKETED BY

MLB

APPLICATION OF NACO WATER
COMPANY, LLC FOR A PERMANENT
INCREASE TO ITS WATER RATES

DOCKET NO: W-02860A-13-0399

**NOTICE OF COMPLIANCE RE
FILING WATER LOSS REPORT**

Pursuant to Decision No. 74900, Naco Water Company, L.L.C. hereby files its
water loss report set forth in Attachment 1.

RESPECTFULLY SUBMITTED this 30th day of June, 2015.

MOYES SELLERS & HENDRICKS LTD.

Steve Wene

1 Original and 13 copies of the foregoing
2 filed this 30th day of June, 2015 with:

3 Docket Control
4 Arizona Corporation Commission
5 1200 West Washington
6 Phoenix, Arizona 85007

7 Donnelly Herbert
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

ATTACHMENT 1

NACO WATER COMPANY

TELEPHONE: (520) 624-1460

FAX: (520) 792-0377

MAILING ADDRESS:

P.O. BOX 85160
TUCSON, AZ 85754

LOCATION:

2015 N FORBES BLVD, SUITE 107
TUCSON, AZ 85745

- March 2015 22% water loss: March 6, 2015 a leak was called in on Hillman Dr. The duration of the leak is unknown but once we were notified it was repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed. A Contractor was pulling water from a hydrant on Newell St with no meter.
- May 2015 33% water loss: April 23, 2015 a leak was called in on Dominguez and on May 23, 2015 a leak was called in on Newell St. at the RV Park. The duration of the leaks is unknown but once we were notified it was repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed.
- June 2015 19% water loss is due to water being hauled to the Bisbee Junction well site for 5 days.

NACO WATER COMPANY

Bisbee Junction

TELEPHONE: (520) 624-1460

FAX: (520) 792-0377

MAILING ADDRESS:

P.O. BOX 85160
TUCSON, AZ 85754

LOCATION:

2015 N FORBES BLVD, SUITE 107
TUCSON, AZ 85745

- January 2015 41% water loss: January 2, 2015 there was a line break on Purdy Lane. The duration of the leak is unknown but once we were notified it was repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed.
- February 2015 29 % water loss: February 19, 2015 a leak was called in on Border Rd. The duration of the leak is unknown but once we were notified it was repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed.
- March 2015 35% water loss: March 27, 2015 a leak was called in on Border Rd. The duration of the leak is unknown but once we were notified it was repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed.
- April 2015 27% water loss: April 16 and April 29, 2015 several leaks were located on Border Rd. The duration of these leaks were unknown but once they were located they were repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed.
- May 2015 24% water loss: May 8, 2015 several leaks were located on Mulberry Rd and Cactus Ln. The duration of these leaks were unknown but once they were located they were repaired. After the repair the system was flushed for water quality purposes until no sediment was noticed.
- June 2015 The Pump and Motor was damaged June 10, 2015 and was replaced June 15, 2015. During this time frame water was hauled in to keep up with the demand.

Bisbee Junction

Month	2015 Water Sold	2015 Water Pumped	Gallons Not Sold But Justified	2015 Water Loss
January	226,000	382,000		40.84%
February	175,000	246,000		28.86%
March	170,000	261,000		34.87%
April	261,000	356,000		26.69%
May	333,000	440,000		24.32%
Total	1,165,000	1,685,000		30.86%

Township

Month	2015 Water Sold	2015 Water Pumped	Gallons Not Sold But Justified	2015 Water Loss
January	1,135,000	1,318,000		13.88%
February	949,000	981,000		3.26%
March	886,000	1,131,000		21.66%
April	1,158,000	1,354,000		14.48%
May	1,399,000	2,095,000		33.22%
Total	5,527,000	6,879,000		19.65%